



**PUBLIC HEALTH ENGINEERING DEPARTMENT  
LABORATORY JHUNJHUNU**

**CHEMICAL EXAMINATION REPORT OF WATER**

No. Lab. / Chem. /2022-23/ 611

Date - 21-11-2022

To,

The Principal

Gudha International School

Jasrapur

Distt:-Jhunjhunu

Tehsil:-Khetri

Ref- Your's letter dated 21-11-2022

Date of Exam -21-11-2022

A	Name & Location of Source		Water Sample Gudha International School Jasrapur
B	Village/ Town		Jasrapur
C	Date Of Collection		21-11-22
D	Lab. Sample No.		C-27
Sr. No	Parameters	Permissible limits	Analysed Value
1	pH	6.5—8.5	7.3
2	Turbidity[NTU]	5	Nil
3	Temperature[C]	-----	25
4	Colour[Units]	25 Hazen Unit	None
5	Odour	Unobjectionable	Unobj.
6	Total Alkalinity[asCaCO <sub>3</sub> ]	600	160
7	Total Hardness[asCaCO <sub>3</sub> ]	600	140
8	Calcium [asCa]		24
9	Magnesium [as Mg]		19.2
10	Chloride[asCl <sup>-1</sup> ]	1000	120
11	Nitrate[as NO <sub>3</sub> <sup>-1</sup> ]	45	11
12	Fluoride [as F <sup>-1</sup> ]	1.5	0.3
13	TDS	2000	480

Note: All Results Except pH in mg/L.

*(S K Sharma)*  
21-11-22

(S K Sharma)  
Junior Chemist

PHED Laboratory Jhunjhunu

Attested

*(S K Sharma)*

सचिव

दयाल शिक्षण सेवा समिति  
जसरापुर, जिला झुन्झुनं

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION**  
**CERTIFICATE.**

No. 611

Date : 21-11-2022

It is certified that an inspection team headed by Surendra Kumar Sharma  
Junior chemist (Name of Officers  
with designation) from PHED Laboratory, Jhunjhunu (Name of  
Department/Office) inspected the Gudha International  
School, Jasrapur (khetri) (Name & Address of  
the School) on 21-11-2022 and found that the Gudha International  
School, Jasrapur (Name of school) has safe  
drinking water facilities for the students and members of staff of the institution and is maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 year.

Signature with Seal : [Signature]  
Name : (सुरेन्द्र कुमार शर्मा)  
कनिष्ठ रसायनज्ञ  
Designation : जन स्वा० अभि० विभाग  
प्रयोगशाला, झुंझुनू

To  
Principal  
Gudha International School  
Jasrapur

(Name & Address of the Institution)

Attested

[Signature]  
साचिव  
दयाल शिक्षण सेवा समिति  
जसरापुर, जिला झुंझुनू